

# Attestation

## LEED v4 and v4.1 BETA

On 3 December 2021, Eurofins Product Testing A/S received a sample of a panel with the product name:

### Techos Metálicos THU

supplied by

### THU Perfil S.L.


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no. 392-2021-00606801\_A\_EN).

**The test results of the tested sample indicate that the product qualifies for LEED v4 and LEED v4.1 BETA (February 2021) projects outside the US by showing compliance with the specifications for VOC emissions by complying with:**

#### **VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects outside the US:**

- The requirements of LEED v4.1 BETA (February 2021) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2018), showing an overall R-value below or equal to 1 and having a TVOC according to EN 16516 below or equal to 1,000  $\mu\text{g}/\text{m}^3$ , a sum of VOC without LCI less than 100  $\mu\text{g}/\text{m}^3$  and a formaldehyde emission below or equal to 10  $\mu\text{g}/\text{m}^3$ ; all after 28 days.
- The requirements of LEED v4 by complying with:
  - The requirements of Indoor Air Comfort Gold version 7.0 (May 2020).

14 January 2022



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*