

# Attestation

## BREEAM®

On 3 December 2021, Eurofins Product Testing A/S received a sample of a panel with the product name:

### Techos Metálicos THU

supplied by


### THU Perfil S.L.

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11 testing standards (See test report no. 392-2021-00606801\_A\_EN and 392-2021-00606801\_A\_EN).

**The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions by complying with:**

- **BREEAM® International: Compliance with Exemplary criteria on VOC emission** of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor Air Quality (version SD233 issue 2.0 of July 2017)
- **BREEAM® UK: Compliance with Exemplary criteria on VOC emission** of BREEAM UK: New Construction 2018, Technical Manual: Hea 02 Indoor Air Quality (version SD5078 issue 3.0 of July 2019)
- **BREEAM® NOR: Compliance with criteria on VOC emission** of BREEAM-NOR 2016 New Construction, Technical Manual SD5075NOR, Hea 02 Indoor Air Quality (version 1.2 of June 2019)

14 January 2022



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry