

Attestation

Italian CAM

On 3 December 2021, Eurofins Product Testing A/S received a sample of a panel with the product name:

Techos Metálicos THU

supplied by

THU Perfil S.L.

The emissions were tested according to the Italian CAM Decree GU n.23 del 28-01-2017. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2021-00606801_A_EN).


Evaluation of the emission test result according to Italian CAM:

- The relevant CMR compounds were not detectable after 28 days.
- The sum of VOC ("TVOC") after 28 days was below the limit of 1500 µg/m³.
- Formaldehyde after 28 days was below the limit of 60 µg/m³.
- All other parameters were below their respective limit values after 28 days.

26 January 2022



Rasmus Verdier
Analytical Service Manager



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry